

# KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

was issued to

**Saudi Electricity Company (SEC) KSA**

Cairo, Egypt

for the test object:

a three-phase oil-filled

**power transformer**

Type: PT-025000-034500-0002

Rating: 20 / 25 MVA – 34,5 kV ± 10% / 13,8 kV – Dyn11 – 60 Hz

manufactured by

**Elsewedy Transformers company**

Cairo, Egypt


The test object has successfully passed the required type tests of  
**IEC 60076-5**

The test results are recorded in Certificate No.

**2096-20**

This Certificate was issued on 4 June 2020.

KEMA B.V.



Shankar Subramany  
Director, High-Power Laboratory