

# Type test Certificate of short-circuit performance

## **Elsewedy cables (Transformers factory)**

10<sup>th</sup> of Ramadan City, Egypt

has successfully passed the type test sequence on an

## **oil immersed power transformer**

Type: SFZ9-125000/220T

Rating: 125/125/45 MVA - 220 kV  $\pm$  8 x 1,25%/72,5 kV/24 kV - 50 Hz

The test object passed the specification of clauses of

## **IEC 60076-5**

The test results are recorded in Certificate No.

## **TDT 2163-10**

This Certificate is issued on 20 December 2010

KEMA Nederland B.V.



P.G.A. Bus  
KEMA T&D Testing Services  
Managing Director

