

Type test Certificate of short-circuit performance

Elsewedy Transformers,

10th of Ramadan, Egypt

has successfully passed the type test sequence on a three-phase

oil immersed power transformer

Rating: 30 MVA – 132 kV (+7x1,5% -13x1,5%) kV / 11,5 kV – Dzn10 –
50 Hz

The test object passed the required clauses of

IEC 60076-5

The test results are recorded in Certificate No.

TIC 2102-12

This Certificate is issued on 17 December 2012

KEMA Nederland B.V.



S.A.M. Verhoeven
Director Testing, Inspections & Certification The Netherlands

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.

